



Division of Environmental Health
 100 Central Avenue
 Cheyenne, WY 82007
 Phone: 307-633-4090
 Fax: 307-633-4038

CPO:	
License Posted:	
Inspection Posted:	Yes
Follow-Up Required:	NO
Date:	06/28/2024
Time:	
Inspector:	20

Recreational Water Inspection

<i>Establishment Information</i>	
Facility Name	Facility Type
Cheyenne Splash Pad	Pool
Facility ID #	Facility Telephone #
CO220319	(307) 638-4358
Facility Address	
121 W 15th St Cheyenne WY 82001	
Licensee Name	CPO
City of Cheyenne	Ezra Gillis 04/30/2023

<i>Inspection Information</i>			
Inspection Type	Inspection Date		
Routine	06/28/2024		

<i>Water Quality Readings</i>					
Free Available Chlorine/Bromine	3.26 /	Combined Chlorine	0.62	Alkalinity	42
pH	7.13	Temperature	789	Cyanuric Acid	
Disinfectant	Chlorine	Total Chlorine	3.88	Water Clarity	Clear

<i>Violations</i>

Comments

All chemicals in proper range

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge



E zu am,

Inspector



James Jones, EHS