

Division of Environmental Health

100 Central Avenue Cheyenne, WY 82007 Phone: 307-633-4090 Fax: 307-633-4038

License Posted: Inspection Posted: Follow-Up Required: NO Date: 07/02/2024 Time: 2:00 PM 20 Inspector:

CPO:

Yes

Recreational Water Inspection

Establishment Information				
Facility Name	Facility Type			
Quality Inn Pool	Pool			
Facility ID #	Facility Telephone #			
CO220306	(307) 638-7202			
Facility Address				
2245 Etchepare Dr Cheyenne 82007				
Licensee Name	CPO			
Nasima Khan Khan Hotels, LLC	Michelle Stout 04/30/2028			

Inspection Information					
Inspection Type	Inspection Date				
Follow-Up	07/02/2024				

Water Quality Readings					
Free Available Chlorine/Bromine	2.34 /	Combined Chlorine	Alkalinity 1	.55	
рН	8.00	Temperature 90	Cyanuric Acid	.35	
Disinfectant	Tri-Chlor	Total Chlorine	Water Clarity Cle	ear	

Violations	
	Dago 1

Comments

Cyanuric still high but is moving down. Continue draining pool and scrubbing sides/bottom of pool to decrease concentration. It is recommended to switch from trichlor to regular chlorine.

Pool cleared to open.

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge

Inspector

Jonah Barker , EHS