



**Division of Environmental Health**  
100 Central Avenue  
Cheyenne, WY 82007  
Phone: 307-633-4090  
Fax: 307-633-4038

CPO:	Yes
License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	05/24/2024
Time:	9:30 AM
Inspector:	13

## Recreational Water Inspection

<b>Establishment Information</b>		
Facility Name	Facility Type	
YMCA Spa	Spa	
Facility ID #	Facility Telephone #	
CO220068	(307) 634-9622	
Facility Address		
1426 E Lincolnway Cheyenne WY 82001		
Licensee Name	CPO	
YMCA	Joel Bridenstine	06/30/2027
YMCA	Marla Ichitasu	12/31/2028

<b>Inspection Information</b>			
Inspection Type	Inspection Date		
Routine	05/24/2024		

<b>Water Quality Readings</b>			
Free Available Chlorine/Bromine	/ 4.06	Combined Chlorine	Alkalinity
pH		Temperature	Cyanuric Acid
Disinfectant		Total Chlorine	Water Clarity

<b>Violations</b>
37) Total Alkalinity: 50 - 250 ppm Observation: Alkalinity was at 29 ppm. Corrective Action(s): Work on increasing the alkalinity and maintaining it between 60 and 180 ppm.

**Comments**

Timely records are being kept.  
Clean and organized spa area, chemical room and pump room.

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge



Inspector



Matthew Hartay, EHS