



Division of Environmental Health
100 Central Avenue
Cheyenne, WY 82007
Phone: 307-633-4090
Fax: 307-633-4038
Childcare Inspection

License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	05/21/2024
Time:	02:45 PM
Inspector:	11,14

Establishment Information	
Facility Name	Facility Type
The Crib	Child Care Center
Facility ID #	Facility Telephone #
CO200538	(307) 632-2822
Facility Address	
611 E Carlson St Ste. 107 Cheyenne WY 82009	
Licensee Name	
Savannah Velasquez The Crib	

Inspection Information			
Inspection Type	Inspection Date		
Follow-Up	05/21/2024		

Violations
2) Sanitary Practices Observation: Mop sink must have backflow preventer installed. Corrective Action(s): Install backflow preventer and email in a picture.
3) Safety Observation: Hot water at back kids hand sink is at 78 degrees F.
5/21- hot water at back kids hand sink at 113 degrees F. (Corrected on Site)
3) Safety Observation: Hot water at one of the children's hand sinks is at 131 degrees F.
5/21- hot water at front kids hand sink is at 112 degrees F. (Corrected on Site)

Comments

- All hand sinks in proper temperature range
- Mop sink faucet is being completely replaced.
- Cleared to open by environmental health.

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge

Inspector

,

Madison Bell, EHS