

## **Division of Environmental Health**

100 Central Avenue Cheyenne, WY 82007 Phone: 307-633-4090

Fax: 307-633-4038

Yes CPO: License Posted: Yes Inspection Posted: Yes Follow-Up Required: NO Date: 11/28/2023 Time: 10,20 Inspector:

## **Recreational Water Inspection**

Establishment Information			
Facility Name	Facility Type		
YMCA Spa	Spa		
Facility ID #	Facility Telephone #		
CO220068	(307) 634-9622		
Facility Address			
1426 E Lincolnway Cheyenne WY 82001			
Licensee Name	СРО		
YMCA	Joel Bridenstine 06/30/2027		

Inspection Information					
Inspection Type	Inspection Date		900 300 300 300 500 500 500 500 500 500 5		
Routine	11/28/2023				

Water Quality Readings					
Free Available Chlorine/Bromine	2.6 /	Combined Chlorine	0.63	Alkalinity	61
рН	7.7	Temperature	100	Cyanuric Acid	
Disinfectant	Chlorine	Total Chlorine	3.23	Water Clarity	Clear

Violations	

## Comments

All chemicals in proper range Good record keeping All equipment appears to be in working order Clean and organized

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge

(AX/

Inspector

Jonah Barker , EHS