



Division of Environmental Health
 100 Central Avenue
 Cheyenne, WY 82007
 Phone: 307-633-4090
 Fax: 307-633-4038

CPO:	Yes
License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	06/26/2024
Time:	8:45 AM
Inspector:	13

Recreational Water Inspection

Establishment Information	
Facility Name	Facility Type
Comfort Suites	Pool
Facility ID #	Facility Telephone #
CO220325	(307) 369-2404
Facility Address	
5410 Walker Rd Cheyenne WY 82009	
Licensee Name	CPO
Cheyenne Hospitality LLC	Kacy James 03/31/2029

Inspection Information			
Inspection Type	Inspection Date		
Routine	06/26/2024		

Water Quality Readings					
Free Available Chlorine/Bromine	5.75 /	Combined Chlorine	1.39	Alkalinity	60
pH	7.21	Temperature	82	Cyanuric Acid	
Disinfectant	Chlorine	Total Chlorine	7.14	Water Clarity	Clear

Violations

29) Records: Daily, Complete, Signed, Accident Reports.
 Observation: Pool records are only being logged 2 times a day.
 Corrective Action(s): Pool must be checked and recorded at opening, every 4 hours and at closing. Work on recording pool chemical checks at the required intervals.

36) Disinfectant in Required Range
 Observation: Combined chlorine tested to be 1.39.
 Corrective Action(s): Combined chlorine must be .5 or lower. Work on lowering and maintaining .5 or lower.

Comments

Recommend installing FRP on walls in the pool mechanical room and coving to prevent water damage. Pool deck clean.

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge

Inspector



Josie Prince, EHS