



**Division of Environmental Health**  
 100 Central Avenue  
 Cheyenne, WY 82007  
 Phone: 307-633-4090  
 Fax: 307-633-4038

CPO:	Yes
License Posted:	
Inspection Posted:	
Follow-Up Required:	YES
Date:	06/26/2024
Time:	10:30 AM
Inspector:	13

## Recreational Water Inspection

<b>Establishment Information</b>	
Facility Name	Facility Type
Spring Hill Suites	Pool
Facility ID #	Facility Telephone #
CO220286	(307) 635-0006
Facility Address	
416 W Fox Farm Rd Cheyenne WY 82009	
Licensee Name	CPO
Springhill Suites Springhill Suites	Lynse Fostmeier 04/30/2028

<b>Inspection Information</b>			
Inspection Type	Inspection Date		
Routine	06/26/2024		

<b>Water Quality Readings</b>			
Free Available Chlorine/Bromine	.49 /	Combined Chlorine	Alkalinity
pH		Temperature	Cyanuric Acid
Disinfectant	Chlorine	Total Chlorine	Water Clarity Clear

<b>Violations</b>
<p>36) Disinfectant in Required Range            Observation: Free chlorine tested to be at .49.            Corrective Action(s): Free chlorine must be between 1 ppm and 8 ppm.</p>

**Comments**

Due to Free chlorine being below the minimum required 1 ppm, the pool is closed. A follow up inspection is required. Contact the inspector when all chemicals are within the required ranges.

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge



Inspector



\*Josie Prince\*, EHS