



Cheyenne
Laramie County
Public Health

Division of Environmental Health

100 Central Avenue
 Cheyenne, WY 82007
 Phone: 307-633-4090
 Fax: 307-633-4038

Recreational Water Inspection

CPO:	Yes
License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	06/26/2024
Time:	
Inspector:	20

Establishment Information	
Facility Name	Facility Type
Johnson Pool	Pool
Facility ID #	Facility Telephone #
CO220031	(307) 637-6239
Facility Address	
812 1/2 House Ave Cheyenne WY 82007	
Licensee Name	CPO
City of Cheyenne City of Cheyenne	Ezra Gillis 04/30/2028

Inspection Information			
Inspection Type	Inspection Date		
Routine	06/26/2024		

Water Quality Readings			
Free Available Chlorine/Bromine	8.13 /	Combined Chlorine	Alkalinity 60
pH	7.21	Temperature 72	Cyanuric Acid
Disinfectant	Chlorine	Total Chlorine	Water Clarity Clear

Violations

Comments

Chlorine slightly high but coming down
No violations observed
Cleared to open

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge



Inspector



James Jones, EHS