



**Division of Environmental Health**  
100 Central Avenue  
Cheyenne, WY 82007  
Phone: 307-633-4090  
Fax: 307-633-4038

CPO:	Yes
License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	05/21/2024
Time:	11:00 AM
Inspector:	20

## Recreational Water Inspection

<b>Establishment Information</b>	
Facility Name	Facility Type
Little America Pool	Pool
Facility ID #	Facility Telephone #
CO220028	(307) 775-8400
Facility Address	
2800 W Lincolnway Cheyenne WY 82003	
Licensee Name	CPO
Little America Little America	William Clark 05/31/2029

<b>Inspection Information</b>			
Inspection Type	Inspection Date		
Routine	05/21/2024		

<b>Water Quality Readings</b>			
Free Available Chlorine/Bromine	4.37 /	Combined Chlorine	Alkalinity 250
pH	7.44	Temperature	Cyanuric Acid 7
Disinfectant	Chlorine	Total Chlorine	Water Clarity Clear

<b>Violations</b>

**Comments**

Work to lower alkalinity  
All other chemicals in proper range  
Good record keeping  
Clean and organized equipment and chemical room

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge



Inspector



Jonah Barker, EHS