



Division of Environmental Health
100 Central Avenue
Cheyenne, WY 82007
Phone: 307-633-4090
Fax: 307-633-4038

CPO:	Yes
License Posted:	Yes
Inspection Posted:	Yes
Follow-Up Required:	YES
Date:	05/23/2024
Time:	9:00 AM
Inspector:	12

Recreational Water Inspection

Establishment Information	
Facility Name	Facility Type
Pine Bluffs Swimming Pool	Pool
Facility ID #	Facility Telephone #
CO220063	(307) 245-3783
Facility Address	
200 E 8th St Pine Bluffs WY 82082	
Licensee Name	CPO
Town of Pine Bluffs	Heather Eggley 04/30/2029

Inspection Information			
Inspection Type	Inspection Date		
Routine	05/23/2024		

Water Quality Readings			
Free Available Chlorine/Bromine	3.49 /	Combined Chlorine	0.14
		Alkalinity	223
pH	7.76	Temperature	82
		Cyanuric Acid	
Disinfectant		Total Chlorine	3.63
		Water Clarity	Clear

Violations
37) Total Alkalinity: 50 - 250 ppm Observation: Alkalinity @ 223 ppm. Corrective Action(s): Continue muriatic acid addition until alkalinity <180 ppm. Call for re-inspection.

Comments

Cleared to open.
Monitor chemical levels until alkalinity reduced <180 ppm.

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge

Inspector

A handwritten signature in black ink, appearing to read 'Ned Karcich', with a long horizontal flourish extending to the right.

Ned Karcich, EHS