



**Division of Environmental Health**  
 100 Central Avenue  
 Cheyenne, WY 82007  
 Phone: 307-633-4090  
 Fax: 307-633-4038

CPO:	Yes
License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	06/06/2024
Time:	
Inspector:	20

## Recreational Water Inspection

<b>Establishment Information</b>	
Facility Name	Facility Type
Westwinds MHP Pool	Pool
Facility ID #	Facility Telephone #
CO220042	(307) 635-6557
Facility Address	
505 Williams St Cheyenne WY 82007	
Licensee Name	CPO
Madison Bullock Westwinds MHP Pool	Jeff Dabb <span style="float: right;">04/30/2029</span>

<b>Inspection Information</b>			
Inspection Type	Inspection Date		
Routine	06/06/2024		

<b>Water Quality Readings</b>			
Free Available Chlorine/Bromine	5.43 /	Combined Chlorine	Alkalinity 62
pH	7.31	Temperature 80	Cyanuric Acid 30
Disinfectant	Chlorine	Total Chlorine	Water Clarity Clear

<b>Violations</b>

**Comments**

All chemicals in proper range  
Equipment/Chemical room clean and organized  
Good record keeping  
Cleared to open for summer

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge



Inspector



Jonah Barker , EHS