



Division of Environmental Health
100 Central Avenue
Cheyenne, WY 82007
Phone: 307-633-4090
Fax: 307-633-4038

CPO:	Yes
License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	05/24/2024
Time:	10:15 AM
Inspector:	13

Recreational Water Inspection

Establishment Information		
Facility Name	Facility Type	
YMCA Pool	Pool	
Facility ID #	Facility Telephone #	
CO220044	(307) 634-9622	
Facility Address		
1426 E Lincolnway Cheyenne WY 82001		
Licensee Name	CPO	
YMCA	Joel Bridenstine	06/30/2027
YMCA	Marla Ichitasu	12/31/2028

Inspection Information			
Inspection Type	Inspection Date		
Routine	05/24/2024		

Water Quality Readings			
Free Available Chlorine/Bromine	2.07 /	Combined Chlorine	1.86
		Alkalinity	113
pH	7.80	Temperature	83
		Cyanuric Acid	
Disinfectant	Chlorine	Total Chlorine	3.93
		Water Clarity	Clear

Violations
35) Samples: Bacteria, Chemical, Taken, Available. Observation: Combined chlorine was tested to be at 1.86. Corrective Action(s): Combined chlorine must be .5 or lower. Ventilation is currently being worked on.

Comments

Work on keeping combined chlorine at .5 or lower.
Clean pool area, chemical room and pump room.
Timely records are being kept.

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge



Inspector



Matthew Hartay, EHS