



Division of Environmental Health
 100 Central Avenue
 Cheyenne, WY 82007
 Phone: 307-633-4090
 Fax: 307-633-4038

CPO:
 License Posted:
 Inspection Posted:
 Follow-Up Required: NO
 Date: 09/18/2024
 Time: 11:00 AM
 Inspector: 10,13

Recreational Water Inspection

Establishment Information	
Facility Name	Facility Type
South High School Pool	Pool
Facility ID #	Facility Telephone #
CO220209	(307) 771-2410
Facility Address	
1213 W Allison Rd Cheyenne WY 82007	
Licensee Name	CPO
LCSD #1 - Facilities Management	Steven Keslar 02/29/2028

Inspection Information			
Inspection Type	Inspection Date		
Routine	09/18/2024		

Water Quality Readings					
Free Available Chlorine/Bromine	3.22 /	Combined Chlorine	0.58	Alkalinity	81
pH	7.4	Temperature	80.2	Cyanuric Acid	
Disinfectant	Chlorine	Total Chlorine	3.8	Water Clarity	Clear

Violations
<p>36) Disinfectant in Required Range Observation: Combined chlorine too high at 0.58 ppm. Corrective Action(s): Combined chlorine must be below 0.50 ppm.</p>

Comments

Combined chlorine too high at 0.58 ppm. Pool area is clean, good record keeping.


Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge



Inspector



Matthew Hartay , EHS