



**Division of Environmental Health**  
 100 Central Avenue  
 Cheyenne, WY 82007  
 Phone: 307-633-4090  
 Fax: 307-633-4038

License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	09/17/2024
Time:	09:00 AM
Inspector:	10,13

## Campground Inspection

<b>Establishment Information</b>	
Facility Name	Facility Type
T-Joe's RV Park	Campground
Facility ID #	Facility Telephone #
CO230287	(307) 635-8750
Facility Address	
12700 E I-80 Service Rd Cheyenne WY 82009	
Licensee Name	
Sherrie Lyle  ST Park LLC	11805 E Four Mile Rd Cheyenne WY 82009

<b>Inspection Information</b>			
Inspection Type	Inspection Date		
Routine	09/17/2024		

<b>Violations</b>
<p>10) Construction maintained            Observation: Coving on far wall of men's bathroom is damaged and is hanging loosely on the floor            Corrective Action(s): Fix coving to prevent growth of mildew and mold.</p>

**Comments**

Bathrooms and showers were clean. Coving in men's shower requires repair.

Failure to make corrections shall result in denial, suspension, or revocation of your license.

Person in Charge

Inspector

,

Matthew Hartay ,EHS