



**Division of Environmental Health**  
 100 Central Avenue  
 Cheyenne, WY 82007  
 Phone: 307-633-4090  
 Fax: 307-633-4038

License Posted:	
Inspection Posted:	
Follow-Up Required:	NO
Date:	07/12/2024
Time:	04:00 PM
Inspector:	13

### Childcare Inspection

<b>Establishment Information</b>	
Facility Name	Facility Type
Mrs Em's Childcare	Family Child Care Home
Facility ID #	Facility Telephone #
CO200526	(307) 221-1738
Facility Address	
2624 Sagebrush Ave Cheyenne WY 82009	
Licensee Name	
Emily Pieper	

<b>Inspection Information</b>			
Inspection Type	Inspection Date		
Follow-Up	07/12/2024		

<b>Violations</b>
<p>3) Safety            Observation: Hand wash sink temperature at 130 degrees F.</p> <p>A repair was conducted and the temperature is now at 105.1 degrees.            Corrective Action(s): Water temperature at hand wash sinks must be between 100 and 120 degrees F.            (Corrected on Site)            Correct-by Date: 07/12/2024</p>

**Comments**

Failure to make corrections shall result in denial, suspension, or revocation of your license.

All critical violations shall be corrected within 10 calendar days. An extension may be granted if the corrective action cannot be completed within 10 days. All extensions must be in writing. Repeat violations requiring additional follow-up inspections may be subject to a **\$100.00** reinspection fee.

Person in Charge

Inspector

James Jones, EHS