

PUBLIC SWIMMING POOL INSPECTION REPORT TENNESSEE DEPARTMENT OF HEALTH DIVISION OF ENVIRONMENTAL HEALTH

ESTABLISHMENT River Plantation 10		DATE 07/27/21	SCORE	
LOCATION 8530 Sawyer Brown Rd		STAFF Miroslava Colmenares	EST. NO. 690112224	96_/100
CITY, STATE, ZIP Nashville TN	37221	TYPE B	PURPOSE Routine	
PERMITTEE			FOLLOW- UP () YI REQUIRED () NO	237

22.

24.

25.

26.

28.

29.

.

4

4

4

4

4

4

4

4

4

4

4

2

PHYSICAL FACILITIES

L.	Bathhouse: floors and walls clean	1
2.	Plumbing fixtures clean, operating properly	1
3.	Toilet tissue in holder, soap, single service towel, air dryer, mirrors non-breakable	1
4.	Approved, adequate, adjusted, repair, clean	1
5.	Adequate lighting, ventilation	2
6	Pool facilities: walls, bottom, decking, walks, fixtures, equipment clean and in good repair	2

Certified lifeguard(s), number, lifeguard chair, number

Personnel, patrons with communicable diseases

Depth markers, diving boards, towers, fencing

General safety: no broken bottles, cans, glass, sharp

Lifeline adequate, constructed, approved material

Main drain, signs, starting blocks, steps, ladders

pH range, total alkalinity, cyanuric acid level

Absence of approved sanitizing residual

Non-breakable thermometer (Type D pools) WATER, WASTE WATER

Visual test, excessive turbidity

Algae control

No foreign material

Water temperature

Water level maintained

٠	30.	Cross connection(s)	4
٠	31.	Sewage disposal	4
•	32.	Water supply, source, approved	4

Sanitizing residual: (ppm), approved chemical test kit

Approved sanitizing, disinfecting methods

2

4

4

2

2

2

ADMINISTRATION

** (33.)	Current permit posted	0
** 34.	Most current inspection report posted	0

WATER QUALITY READINGS

Free Chlorine	2 ppm
Free Bromine	ppm
pH	7.6
Total Alkalinity	ppm
Water Temperature	°F

_			·	
1	Identifi	es cri	tical	items

SAFETY

restricted

Electrical

objects

Telephone

Gas chlorination

Illumination adequate

WATER QUALITY

Lifesaving equipment, adequate

Bacteriological test results positive

Chemical storage, handling

.

٠

٠

٠

٠

٠

٠

.

.

٠

٠

7.

8.

9.

10.

11.

12.

13.

14.

15.

16.

17.

18.

19.

20.

21.

** Identifies misdemeanor violations

Failure to correct any violations of critical items within ten (10) days may result in revocation of your public swimming pool permit. Repeated violation of identical critical item category may result in revocation of your public swimming pool permit. Items identified as constituting imminent health hazards shall be corrected immediately or operations shall cease. You are to post the swimming pool permit and the most recent inspection report in a conspicuous manner. You have the right to request a hearing regarding this report by filing a written request with the Commissioner within ten (10) days of the date of this report. T.C.A. Sections 68-14-307, 68-14-308, 68-14-318, 68-14-321, and 4-5-320.

Signature of Person in Charge

we	gn	file	
----	----	------	--

Ву	Nh	ul	EHS
		00.00 5	

Date of Signature 07/27/2021

Time in/out 03:00 PM

03:20 PM

PUBLIC SWIMMING POOL INSPECTION REPORT TENNESSEE DEPARTMENT OF HEALTH DIVISION OF ENVIRONMENTAL HEALTH



Establishment Information

Establishment Name: River Plantation 10 Establishment Number : 690112224

Observed Violations

Total # 4

6: Deck in poor repair
20: cyan > 100 ppm
33: Most current permit not posted.
34: Most current inspection not posted

***See page at the end of this document for any violations that could not be displayed in this space.

Additional Comments

Cyan ~ 70 ppm

***See page at the end of this document for any extra Additional Comments that could not be displayed in this space.

Establishment Information

Establishment Name: River Plantation 10 Establishment Number : 690112224

Observed Violations (cont'd)

Additional Comments (cont'd)

Source Type: Water

Source: City

What you need to know about...

Protecting your water against waterborne pathogens



Reach out with questions or concerns: Legionella.Health@tn.gov





What is Legionella?

Legionella are bacteria that can cause a serious lung infection called Legionnaires' disease. People can get sick when they inhale water droplets that contain the bacteria.



How does Legionella affect water systems?

Legionella bacteria grow naturally in the environment and in water. They can also grow in building water systems. Buildings with large water systems, like hotels, may be more likely to grow Legionella. If the bacteria are present, they can be spread through aerosols produced by: hot and cold water systems, showerheads, decorative fountains, hot tubs, cooling towers, and more.



Why should you care?

Legionella can potentially grow and spread in building or recreational water systems that can often result in a large number of guests getting sick affecting your business's reputation and income.



What can you do to prevent *Legionella* and other waterborne diseases?

You can protect your guests, staff, and business by assessing your water system and learning about water management programs. Using a water management program can help identify potential hazards in your water system to prevent the growth and spread of harmful bacteria.



Recreational Water Illnesses - What You Should Know.

Preventing recreational water illnesses (RWIs) is possible when operators, patrons, and local health departments work together to ensure compliance with rules and regulations for permitted establishments. Absence or low levels of sanitizing residual in pools, spas, splash pads, and other types of recreational water can result in the spread germs that cause diarrhea as well as skin and respiratory RWIs.



Thinking about Remodeling your **Public Swimming Pool?**

Call your local health department first!



1200-23-5.03 Rule (2) (a) the of Tennessee Public Swimming Pool regulations states that "no person shall begin construction of a public swimming pool or shall alter or reconstruct any public swimming pool without first having submitted plans and specifications to the Department review having received and for approval."

If you plan to remodel, convert, or do any alteration to your pool in the future, contact the health department **FIRST**!

Failure to contact the health department may require expensive and timeconsuming changes.

Call your local county health department and ask for the Environmental Health Program. Contact information for all local health departments in the state can be found at this link.

Or, email geh.health@tn.gov and provide the name and address of the pool you are planning to construct or remodel, and we will have the EHS reach out to you.