

PUBLIC SWIMMING POOL INSPECTION REPORT TENNESSEE DEPARTMENT OF HEALTH DIVISION OF ENVIRONMENTAL HEALTH

ESTABLISHMENT 8th & Berry Apartments			DATE 04/12/24	SCORE
LOCATION 2606 Fessey Park Rd		STAFF Donna Brooks	EST. NO. 690317728	96_/100
CITY, STATE, ZIPTYPEBerry HillTN37204B			PURPOSE Routine	
PERMITTEE			FOLLOW- UP () YI REQUIRED () N	

PHYSICAL FACILITIES

I.	Bathhouse: floors and walls clean	1
2.	Plumbing fixtures clean, operating properly	1
3.	Toilet tissue in holder, soap, single service towel, air dryer, mirrors non-breakable	1
4.	Approved, adequate, adjusted, repair, clean	1
5.	Adequate lighting, ventilation	2
6	Pool facilities: walls, bottom, decking, walks, fixtures, equipment clean and in good repair	2

SA	F	R.	т	v	۰.
3A	r.	e.		x	

*	7.	Certified lifeguard(s), number, lifeguard chair, number	4
۰.	8.	Chemical storage, handling	-4
*	9.	Personnel, patrons with communicable diseases restricted	4
٠	10.	Depth markers, diving boards, towers, fencing	- 4
•	11,	Electrical	4
+	12.	Gas chlorination	- 4
•	13.	General safety: no broken bottles, cans, glass, sharp objects	4
٠	14.	Illumination adequate	- 4
۰.	15.	Lifeline adequate, constructed, approved material	4
۰.	16.	Lifesaving equipment, adequate	4
	17.	Main drain, signs, starting blocks, steps, ladders	-4
٠	18.	Telephone	4

WATER QUALITY

٠	19.	Bacteriological test results positive	4
	20.	pH range, total alkalinity, cyanuric acid level	2
٠	21.	Absence of approved sanitizing residual	4

* Identifies critical items

** Identifies misdemeanor violations

	22	Sanitizing residual: (ppm), approved chemical test kit	2
•	23.	Approved sanitizing, disinfecting methods	4
*	24.	Visual test, excessive turbidity	4
	25.	Algae control	2
	26.	No foreign material	2
	27,	Water level maintained	2
	28.	Water temperature	4
	29.	Non-breakable thermometer (Type D pools)	2

WATER, WASTE WATER

٠	30.	Cross connection(s)	4
٠	31.	Sewage disposal	4
÷	32.	Water supply, source, approved	4

ADMINISTRATION

**	33.	Current permit posted	0
8.4	34.	Most current inspection report posted	0

WATER QUALITY READINGS

Free Chlorine	3.5 ppm
Free Bromine	ppm
pH	7.6
Total Alkalinity	ppm
Water Temperature	°F

Failure to correct any violations of critical items within ten (10) days may result in revocation of your public swimming pool permit. Repeated violation of identical critical item category may result in revocation of your public swimming pool permit. Items identified as constituting imminent health hazards shall be corrected immediately or operations shall cease. You are to post the swimming pool permit and the most recent inspection report in a conspicuous manner. You have the right to request a hearing regarding this report by filing a written request with the Commissioner within ten (10) days of the date of this report. T.C.A. Sections 68-14-307, 68-14-308, 68-14-318, 68-14-321, and 4-5-320.

Signature of Person in Charge

Don Anna

EHS By

Date of Signature 04/12/2024

Time in/out 01:56 PM

02:30 PM

PUBLIC SWIMMING POOL INSPECTION REPORT TENNESSEE DEPARTMENT OF HEALTH DIVISION OF ENVIRONMENTAL HEALTH



Establishment Information

Establishment Name: 8th & Berry Apartments Establishment Number : 690317728

Observed Violations

Total # 2

6: Several cracked stones on pool decking 22: Chlorine level high at 3.5ppm

***See page at the end of this document for any violations that could not be displayed in this space.

Additional Comments

Cyanuric acid levels at 40ppm

Establishment Information


Establishment Name: 8th & Berry Apartments Establishment Number : 690317728

Observed Violations (cont'd)

Additional Comments (cont'd)

What you need to know about ...

Your building water system and Legionella





What is Legionella?

Legionella are bacteria that can cause a serious lung infection called Legionnaires' disease. People can get sick when they inhale water droplets that contain the bacteria.



How does Legionella affect building water?

Legionella bacteria grow naturally in the environment and in water. They can also grow in building water systems. Buildings with large water systems, like hotels, may be more likely to grow Legionella. If the bacteria are present, they can be spread through aerosols produced by: hot and cold water systems, showerheads, decorative fountains, hot tubs, cooling towers, and more.



Why should you care?

Legionella may grow and spread in hotel water systems. Hotels often have a large number of visitors and numerous *Legionella* outbreaks have occurred at hotels. From 2016 to 2017, there were 134 illnesses related to two outbreaks at Tennessee hotels.



What can you do to prevent Legionella?

You can protect your guests and staff by assessing your water system and learning about water management programs. Using a water management program can help identify hazards in your water system and prevent the growth and spread of *Legionella* bacteria.





Thinking about Remodeling your **Public Swimming Pool?**

Call your local health department first!



1200-23-5.03 Rule (2) (a) the of Tennessee Public Swimming Pool regulations states that "no person shall begin construction of a public swimming pool or shall alter or reconstruct any public swimming pool without first having submitted plans and specifications to the Department review having received and for approval."

If you plan to remodel, convert, or do any alteration to your pool in the future, contact the health department **FIRST**!

Failure to contact the health department may require expensive and timeconsuming changes.

Call your local county health department and ask for the Environmental Health Program. Contact information for all local health departments in the state can be found at this link.

Or, email geh.health@tn.gov and provide the name and address of the pool you are planning to construct or remodel, and we will have the EHS reach out to you.