

PUBLIC SWIMMING POOL INSPECTION REPORT TENNESSEE DEPARTMENT OF HEALTH DIVISION OF ENVIRONMENTAL HEALTH

ESTABLISHMENT Radisson Airport - Main Pool		DATE 03/21/24	SCORE
LOCATION 1112 Airport Center Dr	STAFF Keisa Burrell	EST. NO. 690183535	_96_/100
CITY, STATE, ZIP Nashville TN 37214 B		PURPOSE Routine	
PERMITTEE CARLSON HOTELS & RESORTS		FOLLOW- UP (20 Y) REQUIRED () N	S2501

PHYSICAL FACILITIES

Bathhouse: floors and walls clean	1
Plumbing fixtures clean, operating properly	-1
Toilet tissue in holder, soap, single service towel, air dryer, mirrors non-breakable	1
Approved, adequate, adjusted, repair, clean	-1
Adequate lighting, ventilation	2
Pool facilities: walls, bottom, decking, walks, fixtures, equipment clean and in good repair	2
	Plumbing fixtures clean, operating properly Toilet tissue in holder, soap, single service towel, air dryer, mirrors non-breakable Approved, adequate, adjusted, repair, clean Adequate lighting, ventilation Pool facilities: walls, bottom, decking, walks, fixtures,

	22.	Sanitizing residual: (ppm), approved chemical test kit	2
	23.	Approved sanitizing, disinfecting methods	4
*	24.	Visual test, excessive turbidity	4
	25.	Algae control	2
	26.	No foreign material	2
	27.	Water level maintained	2
	28,	Water temperature	4
	29.	Non-breakable thermometer (Type D pools)	2

SAFETY

*	7.	Certified lifeguard(s), number, lifeguard chair, number		
*	8.	Chemical storage, handling	4	
	9.	Personnel, patrons with communicable diseases restricted	4	
+	10.	Depth markers, diving boards, towers, fencing	4	
	11,	Electrical	4	
+	12.	Gas chlorination	4	
	13.	General safety: no broken bottles, cans, glass, sharp objects	4	
٠	14:	Illumination adequate	4	
+	15.	Lifeline adequate, constructed, approved material	4	
*	16.	Lifesaving equipment, adequate	4	
	(17)	Main drain, signs, starting blocks, steps, ladders	4	
	18.	Telephone	4	

WATER, WASTE WATER

30.	Cross connection(s)	4
31.	Sewage disposal	4
32.	Water supply, source, approved	4

ADMINISTRATION

**	33.	Current permit posted	0
9.4	34.	Most current inspection report posted	0

WATER QUALITY

+	19.	Bacteriological test results positive	4
	20.	pH range, total alkalinity, cyanuric acid level	2
*	21.	Absence of approved sanitizing residual	4

^{*} Identifies critical items

WATER QUALITY READINGS

Free Chlorine	2 ppm
Free Bromine	ppm
pH	7.2
Total Alkalinity	40 ppm
Water Temperature	°F

Failure to correct any violations of critical items within ten (10) days may result in revocation of your public swimming pool permit. Repeated violation of identical critical item category may result in revocation of your public swimming pool permit. Items identified as constituting imminent health hazards shall be corrected immediately or operations shall cease. You are to post the swimming pool permit and the most recent inspection report in a conspicuous manner. You have the right to request a hearing regarding this report by filing a written request with the Commissioner within ten (10) days of the date of this report. T.C.A. Sections 68-14-307, 68-14-308, 68-14-321, and 4-5-320.

Signature of Person in Charge Gose Sul

By

EHS

Date of Signature 03/21/2024

Time in/out 02:00 PM

02:20 PM

^{**} Identifies misdemeanor violations

PUBLIC SWIMMING POOL INSPECTION REPORT TENNESSEE DEPARTMENT OF HEALTH DIVISION OF ENVIRONMENTAL HEALTH

Establishment Name: Radisson Airport - Main Pool

Establishment Information

Establishment Number: 690183535



***See page at the end of this document for any violations that could not be displayed in this space. ***Additional Comments 90gpm	bserved Violations				
***See page at the end of this document for any violations that could not be displayed in this space. ***Additional Comments	otal # 1				
Additional Comments	17: Ladder handle loose				
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments					
Additional Comments	**Con page at the end of this docume	nt for any violations the	at could not be displayed in	this snace	
	See page at the end of this docume	nt for any violations the	at could not be displayed in	una apudo.	
90gpm	Additional Comments				
OIT					
	31				

^{***}See page at the end of this document for any extra Additional Comments that could not be displayed in this space.

Establishment Num	ber: 690183535		
01			
Observed Violati	ons (cont'd)		
dditional Com-	nanta (aantidi		
Additional Comm	nents (cont a)		

Establishment Information

Your building water system and Legionella



How to assess your building to protect guests and staff:

- Complete this short worksheet to see if your building is at high risk for Legionella growth: https://www.cdc.gov/legionella/wmp/toolkit/wmp-risk.html
- Learn the basics of a water management program: https://www.cdc.gov/legionella/wmp/overview.html
- Reach out with questions or concerns: Legionella.Health@tn.gov





What is Legionella?

Legionella are bacteria that can cause a serious lung infection called Legionnaires' disease. People can get sick when they inhale water droplets that contain the bacteria.



How does Legionella affect building water?

Legionella bacteria grow naturally in the environment and in water. They can also grow in building water systems. Buildings with large water systems, like hotels, may be more likely to grow Legionella. If the bacteria are present, they can be spread through aerosols produced by: hot and cold water systems, showerheads, decorative fountains, hot tubs, cooling towers, and more.



Why should you care?

Legionella may grow and spread in hotel water systems. Hotels often have a large number of visitors and numerous Legionella outbreaks have occurred at hotels. From 2016 to 2017, there were 134 illnesses related to two outbreaks at Tennessee hotels.



What can you do to prevent Legionella?

You can protect your guests and staff by assessing your water system and learning about water management programs. Using a water management program can help identify hazards in your water system and prevent the growth and spread of *Legionella* bacteria.





Thinking about Remodeling your Public Swimming Pool?

Call your local health department first!



1200-23-5.03 Rule (a) the Tennessee Public Swimming Pool regulations states that "no person shall begin construction of a public swimming pool or shall alter or reconstruct any public swimming pool without first having submitted plans and specifications to the Department review having received and for approval."

If you plan to remodel, convert, or do any alteration to your pool in the future, contact the health department **FIRST**!

Failure to contact the health department may require expensive and time-consuming changes.

Call your local county health department and ask for the Environmental Health Program. Contact information for all local health departments in the state can be found at this link.

Or, email geh.health@tn.gov and provide the name and address of the pool you are planning to construct or remodel, and we will have the EHS reach out to you.