



SCHOOL FACILITY ENVIRONMENTAL SURVEY

TENNESSEE DEPARTMENT OF HEALTH

DIVISION OF ENVIRONMENTAL HEALTH

ESTABLISHMENT Tucker's Crossroads		DATE 10/20/23	SCORE 98 /100
LOCATION Trousedale Ferry Pike	STAFF Paige Bass	EST. NO. 605030132	
CITY, STATE, ZIP Lebanon TN 37090			
PURPOSE Routine			
SCHOOL SYSTEM Wilson County School	MEMBERSHIP 368	FOLLOW-UP () YES REQUIRED (X) NO	

WATER SUPPLY

1.	Approved source	5
----	-----------------	---

DRINKING FACILITIES

2.	Approved type	1
3.	Clean	1
4.	Good repair, properly adjusted	1
5.	Adequate in number	1

GENERAL SAFETY/HEALTH

6.	Clinics clean, orderly, good repair	1
7.	Teaching stations, proper temperature range	1
8.	Recreational equipment safe, good repair	2
9.	Handrails safe, good repair	1
* 10.	Toxic substances properly stored, used	5
* 11.	Electrical outlets, switches protected, visible unsafe wiring	5

PLUMBING

* 12.	Visible cross connections	5
13.	Visible water leaks	1
* 14.	Visible sewage leaks	5
15.	Malfunctioning floor drains	1

INDIVIDUAL SEWAGE DISPOSAL

* 16.	Operating properly	5
-------	--------------------	---

SOLID WASTE

17.	Teaching station containers adequate, clean, good repair	1
18.	Restroom containers adequate, clean, good repair	1
19.	Sanitary napkin containers adequate, clean, good repair	1
20.	Outside storage containers adequate, clean, good repair	2
21.	Approved collection/disposal	1

INSECTS/RODENTS

* 22.	Infestation	5
23.	Control methods	2
24.	Harborage/Attractants	2

CEILINGS/WALLS/FLOORS

25.	Clean	2
26.	Good repair	1

DOORS/WINDOWS

27.	Clean	1
28.	Good repair	1

TEACHING STATIONS/FURNITURE

29.	Clean	1
30.	Good repair	2

LIGHTING/SHADES/BLINDS

31.	Adequate	2
32.	Clean	1
33.	Good repair	2
34.	Properly adjusted	1

STORAGE AREAS/HVAC ROOMS

35.	Custodian closets, equipment rooms and supply rooms clean, orderly	2
36.	Other storage areas clean, orderly	1
37.	HVAC rooms neat, orderly	1

SITE

38.	Free of litter, weeds, dogs	2
39.	Hazardous areas fenced	2
40.	Playground area safe	2
41.	All weather walks	1

RESTROOMS/HANDWASHING

42.	Fixtures operable	2
43.	Walls, floors, ceilings clean	2
44.	Fixtures clean	2
45.	Fixtures good repair	2
46.	Walls, floors, ceilings good repair	2
47.	Fixtures adequate in number	2
48.	Ventilation adequate	1
49.	Toilet tissue provided	2
50.	Soap provided	2
51.	Individual towels provided	2

* Denotes critical items

This is an environmental survey to assess the health and safety conditions at this facility. The Tennessee Department of Health has no regulatory authority over school buildings/grounds; however, the Tennessee Department of Health recommends correction of all critical items within thirty (30) days.

Signature of Person in Charge B. Bass

Date of Signature 10/20/23

By Paige Bass EHS

Time in/out 10:46 AM 11:20 AM

SCHOOL FACILITY ENVIRONMENTAL SURVEY
TENNESSEE DEPARTMENT OF HEALTH
DIVISION OF ENVIRONMENTAL HEALTH



Establishment Information

Establishment Name: Tucker's Crossroads

Establishment Number : 605030132

Observed Violations

Total # 2

45: Hand sink in girls bathroom runs longer than 20 seconds due to push down faucet being stuck in place once pushed to wash hands

Bathroom located in front of library

45: Water faucets in girls bathrooms are not working properly and are loose from mounting; located in front of the kindergarten class room and in front of the main office

***See page at the end of this document for any violations that could not be displayed in this space.

Additional Comments

***See page at the end of this document for any extra Additional Comments that could not be displayed in this space.